

Architectural floor plan of a bathroom. The plan includes a bathtub at the top, a toilet at the bottom left, a shower area at the bottom right, and a central vanity area. Dimensions and annotations are as follows:

- Top Section (Bathtub):** Dimensions 100, 100, 100, 100. Elevation $+5.04$.
- Right Wall:** Dimensions 100, 100. A door is labeled with a circled 8.
- Central Area:** Two rows of fixtures. Left row: $11 \times 15,64 \times 31,10$ and $11 \times 16,27 \times 31$. Right row: $11 \times 15,23 \times 30,45$.
- Bottom Left (Toilet):** Dimensions 100, 100. Elevation $+6.78$. A door is labeled with a circled 48. A note indicates "C 22 450x600 380 W".
- Bottom Right (Shower):** Dimensions 100, 220. A note indicates "przenieść grzejnik płytowy" (move plate heater). A door is labeled "SZACH".
- Bottom Center:** A note indicates "HP - 25".
- Bottom Right (Cabinet):** A note indicates "Szafka hydrantowa wewnętrzna o wym. 1040 x 790 x 170 mm Wnęka o wym. 1100x800x200 mm Spód 70 cm nad posadzką" (Internal fire hydrant cabinet with dimensions 1040 x 790 x 170 mm. Niche with dimensions 1100x800x200 mm. Bottom 70 cm above floor).

Ścianka za plecami skrzynki hydrantu
od strony klatki schodowej
powinna odpowiadać odporności
ogniowej EI 60



**PRZEBUDOWA I REMONT KLATEK SCHODOWYCH W
ZAKRESIE WEWNĘTRZNEJ INSTALACJI WODY P.POŻ. I
CENTRALNEGO OGRZEWANIA W BUDYNKU GŁÓWNYM "A"
SZPITALA SP ZOZ MSW W RZESZOWIE PRZY ULICY
KRAKOWSKIEJ 16 DZ. NR EWID. 1213/1, 1213/5, 1213/7
OBR. 213**

KLATKA POŁUDNIOWA-
I PIĘTRO

16

1: 50

04.2015

А / АААГ